

Annual Groundwater Monitoring and Corrective Action Report

CPS Energy
Calaveras Power Station – Evaporation Pond
San Antonio, Texas

January 2020

www.erm.com

Calaveras Power Station – Evaporation Pond


Annual Groundwater Monitoring and Corrective Action Report

January 2020

Project No. 0503422
San Antonio, Texas



Jeffery L. Bauguss, P.E.
Partner-in-Charge



Walter Zverina
Project Manager



Karen Fletcher
Senior Scientist

Environmental Resources Management
206 East 9th Street, Suite 1700
Austin, TX 78701
T: 512-459-4700

*Texas Registered Engineering Firm F-2393
Texas Board of Professional Geoscientist Firm 50036*

© Copyright 2020 by ERM Worldwide Group Ltd and/or its affiliates (“ERM”). All Rights Reserved. No part of this work may be reproduced or transmitted in any form, or by any means, without the prior written permission of ERM.

TABLE OF CONTENTS

1.	INTRODUCTION.....	1
2.	PROGRAM STATUS.....	2
2.1.	GROUNDWATER FLOW RATE AND DIRECTION.....	2
2.2.	SAMPLING SUMMARY.....	2
2.3.	DATA QUALITY.....	2
3.	STATISTICAL ANALYSIS AND RESULTS.....	3
3.1.	INTERWELL VS INTRAWELL COMPARISONS.....	3
3.2.	ESTABLISHMENT OF UPGRADIENT DATASET.....	3
3.2.1.	Descriptive Statistics.....	4
3.2.2.	Outlier Determination.....	4
3.2.3.	Check for Temporal Stability.....	4
3.3.	CALCULATION OF PREDICTION LIMITS.....	4
3.4.	CONCLUSIONS.....	5
4.	RECOMMENDATIONS.....	6
5.	REFERENCES.....	6

List of Tables

1	Groundwater Elevations Summary
2	Groundwater Sampling Summary
3	Groundwater Analytical Results Summary

List of Figures

1	CCR Well Network Location Map
2	Potentiometric Surface Map – October 2019

List of Appendices

A	Laboratory Data Packages
B	Statistical Analysis Tables and Figures
C	April 2019 Groundwater Sampling Event – Calaveras Power Station CCR Units

1. INTRODUCTION

CPS Energy owns and operates the Calaveras Power Station which consists of two power plants (J.T Deely and J.K. Spruce) that are subject to regulation under Title 40, Code of Federal Regulations, Part 257 (40 CFR §257) (a.k.a. the CCR Rule). The Power Station is located in unincorporated Bexar County, Texas, approximately 13 miles southeast of San Antonio. Currently, CPS Energy operates three CCR units at the Power Station: Evaporation Pond, Fly Ash Landfill, and the Sludge Recycle Holding (SRH) Pond. This *Annual Groundwater Monitoring and Corrective Action Report* (Report) only addresses the Evaporation Pond.

This Report was produced by Environmental Resource Management (ERM), on behalf of CPS Energy, and summarizes the groundwater monitoring activities for the Evaporation Pond and provides a statistical summary of the findings for samples collected during the 2019 semi-annual monitoring events. Consistent with the requirements of the CCR Rule, this Report will be posted to the facility's operating record and notification will be made to the State of Texas. Additionally, this Report will be placed on the CPS Energy publically accessible internet site. Unless otherwise mentioned, the analyses in this Report follow the *Groundwater Sampling and Analysis Program* (SAP) (ERM, 2017) posted on the internet site. The table below cross references the reporting requirements under the CCR Rule with the contents of this Report.

Regulatory Requirement Cross-Reference

Regulatory Citation	Requirement (paraphrased)	Where Addressed in this Report
§257.90(e)	Status of the groundwater monitoring and corrective action program	Section 2
§257.90(e)	Summarize key actions completed	Section 2
§257.90(e)	Describe any problems encountered and actions to resolve problems	Section 2
§257.90(e)	Key activities for upcoming year	Section 4
§257.90(e)(1)	Map or aerial image of CCR unit and monitoring wells	Figure 1
§257.90(e)(2)	Identification of new monitoring wells installed or decommissioned during the preceding year	Section 2
§257.90(e)(3)	Summary of groundwater data, monitoring wells and dates sampled, and whether sample was required under detection or assessment monitoring	Sections 2 and 3, Tables 1 through 3, and Figure 2
§257.90(e)(4)	Narrative discussion of any transition between monitoring programs	Section 4

The Evaporation Pond is located northeast of the Power Station generating units and is south of the Fly Ash Landfill. The Evaporation Pond currently receives boiler chemical cleaning waste and other authorized liquid wastes. The Evaporation Pond was originally constructed as a fly ash landfill, but was converted from a landfill to an impoundment in 1996. The CCR unit location is shown on Figure 1.

2. PROGRAM STATUS

From December 2016 to October 2017, groundwater samples were collected as part of background sampling. After October 2017, groundwater samples were collected as part of detection monitoring. The samples were collected from the groundwater monitoring well network certified for use in determining compliance with the CCR Rule.

The groundwater monitoring well network consists of three upgradient monitoring wells (JKS-47, JKS-63R, and JKS-64) and three downgradient monitoring wells (JKS-36, JKS-61, and JKS-62). As discussed in further detail below, upgradient monitor well JKS-63 was plugged and abandoned and replaced with a newly installed upgradient monitor well (JKS-63R). All monitoring wells are screened within the uppermost groundwater bearing unit (GWBU). The uppermost GWBU is approximately 20 feet thick and is comprised of clayey/silty sand to well-sorted sand. The uppermost GWBU is located below unconfined units (i.e., sands, silts, and low to medium plasticity clays), and above a high plasticity clay (lower confining unit).

The monitoring well locations are shown in Figure 1. No problems were encountered in the data collection or in well performance with the exception of upgradient monitor well JKS-63. A groundwater sample was not collected from JKS-63 during the April 2019 sampling event due to a blockage in the well casing. Upon further inspection of the blockage, it was discovered that tree roots had entered the well which prevented sample collection. JKS-63 was plugged and abandoned and replaced in the well network with JKS-63R on May 2, 2019.

2.1. GROUNDWATER FLOW RATE AND DIRECTION

Depth to groundwater surface measurements were made at each monitoring well prior to sampling. Groundwater elevations were calculated by subtracting the depth to groundwater from the surveyed reference elevation for each well.

Groundwater elevations collected during the monitoring events are summarized in Table 1. Groundwater elevations and the potentiometric surface for the most recent monitoring event (October 2019) are shown on Figure 2. Groundwater in the vicinity of the Evaporation Pond appears to flow towards Lake Calaveras (east). The horizontal gradient is approximately 0.002 feet/foot.

2.2. SAMPLING SUMMARY

A summary of the total number of samples collected from each monitoring well is provided in Table 2. Groundwater analytical results from the monitoring events are summarized in Table 3. Laboratory data packages are provided in Appendix A.

The Evaporation Pond monitoring wells were sampled by CPS Energy using low flow sampling techniques during the monitoring events. With the exception of JKS-63 (as noted above), no data gaps were identified during the 2019 semi-annual groundwater monitoring events. An initial sample, identified as Event 11, was collected at JKS-63R on August 20, 2019.

2.3. DATA QUALITY

ERM reviewed field and laboratory documentation to assess the validity, reliability and usability of the analytical results. Samples were sent to Xenco Laboratories, located in San Antonio, Texas for analysis. Data quality information reviewed for these results included field

sampling forms, chain-of-custody documentation, holding times, lab methods, cooler temperatures, laboratory method blanks, laboratory control sample recoveries, field duplicate samples, matrix spikes/matrix spike duplicates, quantitation limits, and equipment blanks. A summary of the data qualifiers are included in Table 3. The data quality review found the results to be valid, reliable, and useable for decision making purposes with the listed qualifiers. No analytical results were rejected.

3. STATISTICAL ANALYSIS AND RESULTS

Consistent with the CCR Rule and the SAP, a prediction limit approach [40 CFR §257.93(f)] was used to identify potential impacts to groundwater. Tables and figures generated as part of the statistical analysis are provided in Appendix B. The steps outlined in the decision framework in the SAP include:

- Interwell versus intrawell comparisons;
- Establishment of upgradient dataset;
- Calculation of prediction limits; and
- Conclusions.

The remaining sections of this Report are focused on evaluation of the October 2019 sampling results. Note the April 2019 sampling results were evaluated as discussed in the *April 2019 Groundwater Sampling Event – Calaveras Power Station CCR Units* (ERM, 2019) provided in Appendix C.

3.1. INTERWELL VS INTRAWELL COMPARISONS

When multiple upgradient wells were available within the same unit, concentrations were compared among these wells to determine if they could be pooled to create a single, interwell, upgradient dataset. For each analyte, Boxplots (Appendix B, Figure 1) and Kruskal-Wallis test results (Appendix B, Table 1) are provided for upgradient wells. The statistical test shows that:

- One Appendix III analyte [fluoride] will follow interwell analysis, with no significant differences present in upgradient data; and
- The remaining six Appendix III analytes [boron, calcium, chloride, pH, sulfate, and total dissolved solids (TDS)] will follow intrawell analysis, with significant differences present in upgradient data.

Interwell analytes will use a pooled upgradient dataset for subsequent report sections. Conversely, intrawell analytes will have each individual upgradient dataset used for subsequent report sections.

3.2. ESTABLISHMENT OF UPGRADIENT DATASET

When evaluating the concentrations of analytes in groundwater, USEPA Unified Guidance (2009) recommends performing a careful quality check of the data to identify any anomalies. In addition to the data validation that was performed, descriptive statistics, outlier testing, and temporal stationarity checks were completed to finalize the upgradient dataset.

3.2.1. Descriptive Statistics

Descriptive statistics were calculated for the upgradient wells and analytes at the Evaporation Pond (Appendix B, Table 2). The descriptive statistics highlight a number of relevant characteristics about the upgradient datasets including:

- There are a total of 19 well-analyte combinations for the upgradient dataset;
- 19 well-analyte combinations have detection rates greater than or equal to 50 percent;
- 17 well-analyte combinations have 100 percent detects;
- Nine well-analyte combinations follow a normal distribution (using Shapiro-Wilks Normality Test);
- Two well-analyte combinations follow a log-normal distribution; and
- Eight well-analyte combinations have no discernible distribution.

3.2.2. Outlier Determination

Both statistical and visual outlier tests were performed on the upgradient datasets. Data points identified as both a statistical and visual outlier (Appendix B, Table 3 and Appendix B, Figure 2) were reviewed before they were excluded from the dataset. A total of seven potential outliers were initially flagged in the upgradient datasets. However, these values were consistent with seasonal fluctuations and concentrations detected in other upgradient wells or in historical groundwater sampling results. No analytical or sampling issues were identified during data review; therefore, the seven values were considered valid and were retained for upper prediction limit (UPL) calculations.

3.2.3. Check for Temporal Stability

A trend test was performed for all values in the upgradient wells that had at least eight detected data points and at least 50 percent detection rate. Time series figures of upgradient wells are provided in Appendix B, Figure 3. Additionally, the Mann Kendall trend test results are provided in Appendix B, Table 4. The following summarizes the results of the trend analysis:

- There are a total of 19 well-analyte combinations in the upgradient dataset;
- 19 well-analyte combinations meet the data requirements of the trend test of which:
 - One well-analyte combination had a significant increasing trend;
 - Two well-analyte combinations had a significant decreasing trend; and
 - 16 well-analyte combinations had no significant trend (i.e., concentrations were stable over time).

3.3. CALCULATION OF PREDICTION LIMITS

A multi-part assessment of the monitoring wells was performed to determine what type of UPL to calculate as a compliance point. A decision framework was applied for each upgradient well based on inter/intrawell analysis, data availability, and presence of temporal trends.

A total of three well-analyte combinations were found to have either increasing or decreasing trends. For these well-analyte combinations, a bootstrapped UPL calculated around a Theil Sen trend was used to derive a more accurate UPL. The remaining 16 well-analyte combinations

were found to have no significant trend. Sanitas was used to calculate static UPLs using an annual site-wide false positive rate of 0.1 with a 1-of-2 re-testing approach.

A final UPL was selected for each analyte and compared to the October 2019 sampling results in the downgradient wells. A final lower prediction limit (LPL) was also selected for pH. For the one analyte following interwell analysis, the upgradient dataset was pooled prior to UPL calculations, resulting in a single UPL value per analyte. For the six analytes following intrawell analysis, a UPL value was calculated for each of the upgradient wells. For these wells and analytes, the maximum UPL was selected as the representative UPL for each analyte. A similar approach was used to determine the LPL for pH; however, the minimum LPL was selected in the case of intrawell analysis. All final UPL and LPL values are shown in the table below. Full upgradient well calculations are provided in Appendix B, Table 5.

Final UPL and LPL Values

Analysis Type	Analyte	LPL	UPL	Unit
Intrawell	Boron	--	1.88	mg/L
Intrawell	Calcium	--	1,300	mg/L
Intrawell	Chloride	--	2,780	mg/L
Interwell	Fluoride	--	0.382	mg/L
Intrawell	pH	4.58	6.47	SU
Intrawell	Sulfate	--	2,110	mg/L
Intrawell	TDS	--	6,660	mg/L

3.4. CONCLUSIONS

The downgradient samples collected during the October 2019 monitoring event were used for compliance comparisons. All downgradient wells were below the UPLs and above the LPLs with the following exceptions shown in the table below. Full downgradient results are provided in Appendix B, Table 6.

Downgradient Results Exceedances

Analyte	Well	LPL	UPL	Sample Date	Value	Unit
Boron	JKS-61	--	1.88	2019-10-22	2.90	mg/L
Fluoride	JKS-36	--	0.382	2019-10-22	1.41	mg/L
Fluoride	JKS-61	--	0.382	2019-10-22	0.48	mg/L
pH	JKS-36	4.58	6.47	2019-10-22	3.66	SU

All initial exceedances of the UPL and LPL may be confirmed with re-testing of the downgradient wells per the 1-of-2 re-testing scheme. If the initial exceedance is confirmed with re-testing results from the same well, the well-analyte combination will be declared a statistically significant increase (SSI) above background. Any wells with re-testing results at or below the UPL, or at or above the LPL, will be considered in compliance and will not require further action. Any resampling results will be reported in the subsequent *Written Demonstration*.

All downgradient wells with initial exceedances were examined for trends to assess the stability of concentrations. A summary of these trend test results are provided in Appendix B, Figure 4. One of the downgradient wells with potential SSIs has an increasing trend (fluoride) and a decreasing trend (pH).

4. RECOMMENDATIONS

Currently, there are no plans to transition from detection monitoring to assessment monitoring. Consistent with the 1-of-2 re-testing approach described in the Unified Guidance and the SAP, initial exceedances may be re-tested within 90 days. Based on these re-testing results, if an SSI is found, a notification or *Written Demonstration* will be prepared within 90 days. Based on the findings of the *Written Demonstration*, detection monitoring or assessment monitoring will be initiated as appropriate under §257.94 and §257.95.

5. REFERENCES

ERM, 2017. *Groundwater Sampling and Analysis Program*. Austin, Texas.

USEPA, 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities*. Unified Guidance. USEPA/530/R/09/007. Office of Resource Conservation and Recovery. Washington, D.C.

Tables

TABLE 1
Groundwater Elevations Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

Sampling Event	Sampling Event Dates	JKS-47 Upgradient (1)		JKS-63 Upgradient		JKS-63R Upgradient		JKS-64 Upgradient	
		TOC Elevation	513.63	TOC Elevation	526.86	TOC Elevation	522.27	TOC Elevation	507.84
		Depth to Water (feet btoc)	Water Level (msl)	Depth to Water (feet btoc)	Water Level (msl)	Depth to Water (feet btoc)	Water Level (msl)	Depth to Water (feet btoc)	Water Level (msl)
1	12/6/16 to 12/8/16	30.98	482.65	44.45	482.41	(4)	(4)	24.98	482.86
2	2/21/17 to 2/23/17	30.64	482.99	44.25	482.61	(4)	(4)	24.24	483.60
3	3/28/17 to 3/30/17	30.47	483.16	44.12	482.74	(4)	(4)	24.21	483.63
4	5/2/17 to 5/4/17	30.29	483.34	43.89	482.97	(4)	(4)	24.46	483.38
5	6/20/17 to 6/21/17	30.40	483.23	43.85	483.01	(4)	(4)	24.40	483.44
6	7/25/17 to 7/26/17	30.62	483.01	44.00	482.86	(4)	(4)	24.78	483.06
7	8/29/17 to 8/30/17	30.50	483.13	43.90	482.96	(4)	(4)	25.70	482.14
8	10/10/17 to 10/11/17	30.71	482.92	44.05	482.81	(4)	(4)	24.95	482.89
9	4/4/18 to 4/5/18	30.42	483.21	43.81	483.05	(4)	(4)	24.67	483.17
10	10/30/18 to 10/31/18	30.90	482.73	(2)	(2)	(4)	(4)	25.46	482.38
11	4/9/19 to 4/10/19	30.17	483.46	(2)	(2)	39.27 (4)	483.00	24.50	483.34
12	10/22/19 to 10/23/19	30.87	482.76	(3)	(3)	39.48	482.79	25.30	482.54

Sampling Event	Sampling Event Dates	JKS-36 Downgradient		JKS-61 Downgradient		JKS-62 Downgradient	
		TOC Elevation	508.41	TOC Elevation	505.51	TOC Elevation	509.84
		Depth to Water (feet btoc)	Water Level (msl)	Depth to Water (feet btoc)	Water Level (msl)	Depth to Water (feet btoc)	Water Level (msl)
1	12/6/16 to 12/8/16	25.99	482.42	23.95	481.56	28.63	481.21
2	2/21/17 to 2/23/17	25.78	482.63	23.31	482.20	28.30	481.54
3	3/28/17 to 3/30/17	25.37	483.04	23.10	482.41	28.42	481.42
4	5/2/17 to 5/4/17	43.89	464.52	22.85	482.66	28.00	481.84
5	6/20/17 to 6/21/17	25.40	483.01	22.05	483.46	28.05	481.79
6	7/25/17 to 7/26/17	25.62	482.79	23.50	482.01	28.12	481.72
7	8/29/17 to 8/30/17	25.70	482.71	23.60	481.91	28.12	481.72
8	10/10/17 to 10/11/17	25.91	482.50	23.97	481.54	28.00	481.84
9	4/4/18 to 4/5/18	25.46	482.95	23.08	482.43	27.66	482.18
10	10/30/18 to 10/31/18	25.90	482.51	23.94	481.57	28.33	481.51
11	4/9/19 to 4/10/19	25.23	483.18	22.97	482.54	27.52	482.32
12	10/22/19 to 10/23/19	25.90	482.51	24.20	481.31	27.85	481.99

NOTES:

btoc = below top of casing

msl = mean sea level

(1) JKS-47 was re-sampled on 2/28/17.

(2) Blockage in JKS-63 well casing.

(3) JKS-63 was plugged and abandoned on 5/2/19.

(4) JKS-63R was installed on 5/2/19; initial water level reading collected on 8/20/19.

TABLE 2
Groundwater Sampling Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

CCR Unit	Well ID	Well Function	Number of Samples Collected in 2016 - 2019	2016 - 2019 Sample Dates												Monitoring Program
				12/6/16 to 12/8/16	2/21/17 to 2/23/17	3/28/17 to 3/30/17	5/2/17 to 5/4/17	6/20/17 to 6/21/17	7/25/17 to 7/26/17	8/29/17 to 8/30/17	10/10/17 to 10/11/17	4/4/18 to 4/5/18	10/30/18 to 10/31/18	4/9/19 to 4/10/19	10/22/19 to 10/23/19	
Evaporation Pond	JKS-36	Downgradient Monitoring	12	X	X	X	X	X	X	X	X	X	X	X	X	Detection
	JKS-47	Upgradient Monitoring	12	X	(1)	X	X	X	X	X	X	X	X	X	X	Detection
	JKS-61	Downgradient Monitoring	12	X	X	X	X	X	X	X	X	X	X	X	X	Detection
	JKS-62	Downgradient Monitoring	12	X	X	X	X	X	X	X	X	X	X	X	X	Detection
	JKS-63	Upgradient Monitoring	8	X	X	X	X	(2)	X	X	X	X	(3)	(3)	(3)	Detection
	JKS-63R (4)	Upgradient Monitoring	2	(4)	(4)	(4)	(4)	(4)	(4)	(4)	(4)	(4)	(4)	X (4)	X	Detection
	JKS-64	Upgradient Monitoring	12	X	X	X	X	X	X	X	X	X	X	X	X	Detection

NOTES:

X = Indicates that a sample was collected.

(1) JKS-47 was re-sampled on 2/28/2017.

(2) A sample was not collected at JKS-63 during Event 5 (June 2017), due to the well going dry during sampling activities.

(3) A sample was not collected at JKS-63 during Event 10 (October 2018) and Event 11 (April 2019), due to blockage in the well casing. JKS-63 was plugged and abandoned on 5/2/19.

(4) JKS-63R was installed on 5/2/19; the first sample was collected on 8/20/19.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-47 Upgradient											
Sample Date		12/8/16	2/28/17	3/29/17	5/3/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/30/18	4/10/19	10/23/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Apr 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	0.824	0.838	0.696	0.817	0.804	0.828 JH	0.760	1.02	0.844	0.806	0.590	1.05
Calcium	mg/L	54.0	62.1	168	26.2	71.1	62.7 JH	66.7	36.1	53.5	83.2 D	128	36.5
Chloride	mg/L	107	150	232 D	193	168	148 JH	210 D	68.5	151	186	279	53.9 X
Fluoride	mg/L	0.0360 U	0.0360 U	0.315	0.382 JH	0.213 JH	0.360 U	0.0960 U	0.0360 U	0.0360 U	0.0998 J	0.0985 J	0.154 JH
Sulfate	mg/L	213 D	267 D	369 D	299	266 D	248 JH	284 D	171	236	262	347	210 X
pH - Field Collected	SU	5.82	5.83	5.75	6.00	5.75	5.85	5.90	5.93	5.91	5.72	5.92	4.58
Total dissolved solids	mg/L	811	922	1170	1060	979	806 JH	904	677	787	727	1240	665
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.00120 U	0.000240 U	0.000294 J	0.00120 U	0.000275 J	0.000240 U	0.000240 U	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.00442 J	0.00130 J	0.00136 J	0.00123 U	0.00185 J	0.00105 J	0.00124 J	0.000246 U	NR	NR	NR	NR
Barium	mg/L	0.0475	0.0132	0.0180	0.0118 J	0.0154	0.00981	0.0104	0.00785	NR	NR	NR	NR
Beryllium	mg/L	0.000813 J	0.000255 J	0.000131 U	0.000654 U	0.000352 J	0.000131 U	0.000172 J	0.000131 U	NR	NR	NR	NR
Cadmium	mg/L	0.000734 U	0.000637 J	0.000977 J	0.000797 J	0.000735 J	0.000611 J	0.000814 J	0.000147 U	NR	NR	NR	NR
Chromium	mg/L	0.234	0.00430	0.000988 J	0.00262 U	0.00262 J	0.000855 J	0.00130 J	0.000525 U	NR	NR	NR	NR
Cobalt	mg/L	0.00915 J	0.00102 J	0.00153 J	0.00113 J	0.00227	0.000976 J	0.00107 J	0.0000699 U	NR	NR	NR	NR
Fluoride	mg/L	0.0360 U	0.0360 U	0.315	0.382 JH	0.213 JH	0.360 U	0.0960 U	0.0360 U	NR	NR	NR	NR
Lead	mg/L	0.00586 J	0.000950 J	0.000448 J	0.000758 U	0.00157 J	0.000202 J	0.000449 J	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.0615	0.0478	0.00238 U	0.0207	0.0720	0.0644	0.0799	0.0521	NR	NR	NR	NR
Mercury	mg/L	0.0000600 J	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	NR	NR	NR	NR
Molybdenum	mg/L	0.0317	0.00126 J	0.00173 J	0.00128 J	0.000788 J	0.000581 J	0.000653 J	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.0493	0.0697	0.0518	0.0564	0.0613	0.0577	0.0525	0.0854	NR	NR	NR	NR
Thallium	mg/L	0.00166 U	0.000332 U	0.000332 U	0.00166 U	0.000332 U	0.000332 U	0.000332 U	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	1.2 ± 0.342	0.578 ± 0.275	0.630 ± 0.237	0.538 ± 0.192	0.729 ± 0.278	0.304 ± 0.233	1.06 ± 0.361	0.246 ± 0.180	NR	NR	NR	NR
Radium-228	pCi/L	1.66 ± 1.15	1.34 ± 1.05	1.27 ± 0.960 U	2.17 ± 1.01	0.664 ± 0.929	0.771 ± 1.48	1.65 ± 1.05	0.463 ± 0.886	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.

NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-63 / JKS-63R Upgradient (A)											
Sample Date		12/8/16	2/22/17	3/29/17	5/3/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/30/18	8/20/19	10/23/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Aug 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	0.800	0.866	NR	0.981	(1)	1.33 JH	1.23	1.06	1.13	(2)	2.03	1.03
Calcium	mg/L	783	914	713	1060	(1)	835	174	872	836	(2)	221	953 D
Chloride	mg/L	1230 D	1160 D	1220 D	1340	(1)	1960 JHD	1890 D	1420	1670	(2)	2360 D	2240
Fluoride	mg/L	0.0573 J	0.320	0.297	0.364 JH	(1)	0.0971 JH	0.182 JH	0.0360 U	0.0360 U	(2)	0.206 J	0.352 JH
Sulfate	mg/L	0.0460 U	1860 D	1890 D	1860	(1)	1970 D	1920 D	1820	2110	(2)	1810 D	1750 D
pH - Field Collected	SU	5.61	5.35	5.60	5.85	(1)	5.88	5.82	5.63	5.64	(2)	--	4.76
Total dissolved solids	mg/L	5750	4760	4870	5560	(1)	6410	5000	5080	5220	(2)	6660	5200
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.00120 U	0.000459 J	0.000695 J	0.00120 U	(1)	0.000240 U	0.000424 J	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.00332 J	0.00294	0.00128 J	0.00123 U	(1)	0.000893 J	0.000992 J	0.000246 U	NR	NR	NR	NR
Barium	mg/L	0.0626	0.0540	0.0336	0.0316	(1)	0.0294	0.0258	0.0222	NR	NR	NR	NR
Beryllium	mg/L	0.000654 U	0.000930 J	0.000442 J	0.000654 U	(1)	0.000196 J	0.000223 J	0.000131 U	NR	NR	NR	NR
Cadmium	mg/L	0.00339 J	0.00405	0.00394	0.00316 J	(1)	0.00282	0.00263	0.00285	NR	NR	NR	NR
Chromium	mg/L	1.49	0.735	0.371	0.114	(1)	0.0742	0.0584	0.0130	NR	NR	NR	NR
Cobalt	mg/L	0.0802	0.0762	0.0546	0.0331	(1)	0.0137	0.0119	0.0119	NR	NR	NR	NR
Fluoride	mg/L	0.0573 J	0.320	0.297	0.364 JH	(1)	0.0971 JH	0.182 JH	0.0360 U	NR	NR	NR	NR
Lead	mg/L	0.00441 J	0.00599	0.00108 J	0.000758 U	(1)	0.000238 J	0.000551 J	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.000476 U	0.116	0.00238 U	0.654	(1)	0.946	1.15	0.791	NR	NR	NR	NR
Mercury	mg/L	0.000236	0.000237	0.000206	0.0000400 J	(1)	0.000260	0.000441	0.000376	NR	NR	NR	NR
Molybdenum	mg/L	0.186	0.00789	0.00966	0.00419 J	(1)	0.00281	0.00180 J	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.0188	0.0210	0.0257	0.0188	(1)	0.0288	0.0318	0.0244	NR	NR	NR	NR
Thallium	mg/L	0.00166 U	0.000332 U	0.000332 U	0.00166 U	(1)	0.000332 U	0.000332 U	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	3.42 ± 0.573	2.76 ± 0.476	5.79 ± 0.790	4.57 ± 0.577	(1)	6.7 ± 0.744	7.36 ± 0.874	5.04 ± 0.711	NR	NR	NR	NR
Radium-228	pCi/L	2.44 ± 1.44	4.13 ± 1.21	2.04 ± 1.61 U	3.41 ± 0.968	(1)	10.9 ± 2.31	1.79 ± 1.27	6.77 ± 1.48	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.

NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-64 Upgradient											
Sample Date		12/8/16	2/23/17	3/29/17	5/4/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/30/18	4/10/19	10/23/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Apr 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	0.839	0.837	1.14	0.962	0.816	0.904 JH	0.835	0.901	0.837	0.805	0.804	0.747
Calcium	mg/L	24.0	24.0	31.4	23.8	20.6	21.7 JH	21.6	25.2	23.6	24.4	23.0	24.4
Chloride	mg/L	12.7	12.4	11.8	11.0	11.4	11.5	11.5	9.63	14.2	15.5	16.6	17.7
Fluoride	mg/L	0.0360 U	0.294 JH	0.332	0.188	0.231 JH	0.157 JH	0.224 JH	0.0360 U	0.0360 U	0.106 J	0.121 J	0.176 JH
Sulfate	mg/L	171	182	184	174	172	170 JH	172	164	189	196	193	192 X
pH - Field Collected	SU	6.46	5.50	6.30	6.33	6.21	6.09	6.20	6.21	6.13	5.97	6.14	4.82
Total dissolved solids	mg/L	594	585	611	581	572	555 JH	463	576	549	525	551	588
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.000240 U	0.000240 U	0.000240 U	0.00120 U	0.000240 U	0.000240 U	0.000240 U	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.000911 J	0.000730 J	0.000556 J	0.00123 U	0.000476 J	0.000490 J	0.000519 J	0.000246 U	NR	NR	NR	NR
Barium	mg/L	0.00768	0.00451	0.00392 J	0.00410 J	0.00320 J	0.00324 J	0.00275 BJ	0.000484 U	NR	NR	NR	NR
Beryllium	mg/L	0.000131 U	0.000131 U	0.000131 U	0.000654 U	0.000131 U	0.000131 U	0.000131 U	0.000131 U	NR	NR	NR	NR
Cadmium	mg/L	0.000147 U	0.000147 U	0.000147 U	0.000734 U	0.000147 U	0.000147 U	0.000147 U	0.000147 U	NR	NR	NR	NR
Chromium	mg/L	0.000525 U	0.000905 J	0.000525 U	0.00262 U	0.000867 J	0.000637 J	0.000961 J	0.000525 U	NR	NR	NR	NR
Cobalt	mg/L	0.000998 J	0.000952 J	0.000851 J	0.000859 J	0.000745 J	0.000856 J	0.000889 J	0.0000699 U	NR	NR	NR	NR
Fluoride	mg/L	0.0360 U	0.294 JH	0.332	0.188	0.231 JH	0.157 JH	0.224 JH	0.0360 U	NR	NR	NR	NR
Lead	mg/L	0.000186 J	0.000152 U	0.000152 U	0.000758 U	0.000152 U	0.000152 U	0.000152 U	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.0173 J	0.0146 J	0.00238 U	0.0152 J	0.0173 J	0.0181 J	0.0252	0.0208	NR	NR	NR	NR
Mercury	mg/L	0.0000263 UX	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000540 J	0.0000263 U	NR	NR	NR	NR
Molybdenum	mg/L	0.000398 J	0.000317 J	0.000255 U	0.00128 U	0.000265 J	0.000255 U	0.000273 J	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.000512 J	0.000550 J	0.000495 J	0.00227 U	0.000468 J	0.000468 J	0.000454 U	0.000454 U	NR	NR	NR	NR
Thallium	mg/L	0.000332 U	0.000332 U	0.000332 U	0.00166 U	0.000332 U	0.000332 U	0.000332 U	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	0.981 ± 0.400	1.16 ± 0.408	0.530 ± 0.284	0.231 ± 0.174	0.258 ± 0.175	0.286 ± 0.247	1.05 ± 0.361	0.531 ± 0.276	NR	NR	NR	NR
Radium-228	pCi/L	0.429 ± 1.56	2.07 ± 1.22	-0.102 ± 1.07 U	0.408 ± 0.764	0.699 ± 0.761	2.49 ± 1.54	0.26 ± 0.639	1 ± 0.834	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.

NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-36 Downgradient											
Sample Date		12/8/16	2/23/17	3/29/17	5/4/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/30/18	4/10/19	10/22/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Apr 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	0.308	0.671	0.748	0.731	0.581	0.625 JH	0.663	0.637	0.625	0.686	0.663	0.632
Calcium	mg/L	69.7	165	147	282	247	255 JHX	241	289	281	311 D	315 D	265 D
Chloride	mg/L	14.5	199 D	37.0	355	364 D	379 JHD	319 D	328	347 X	313	285	274
Fluoride	mg/L	0.0360 U	0.439 JH	0.330	1.53	1.26	1.37 JH	1.30	1.32	1.95 X	1.47	1.45	1.41
Sulfate	mg/L	49.2	409 D	271 D	726	731 D	775 JHD	707 D	741	816 X	946	697	756 D
pH - Field Collected	SU	6.71	4.96	6.98	4.04	3.72	3.80	5.20	3.24	3.48	3.61	3.71	3.66
Total dissolved solids	mg/L	368	1010	591	1610	1820	1700 JH	1220	1770	1650	1630	1520	1600
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.00120 U	0.000240 U	0.00123 J	0.00120 U	0.000240 U	0.00121 J	0.000240 U	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.00123 U	0.000588 J	0.00134 J	0.00324 J	0.00276	0.00369	0.00341	0.00372	NR	NR	NR	NR
Barium	mg/L	0.0988	0.0967	0.139	0.0270	0.0187	0.0207	0.0372	0.0225	NR	NR	NR	NR
Beryllium	mg/L	0.000654 U	0.00198 J	0.000131 U	0.0259	0.0226	0.0261	0.0212	0.0259	NR	NR	NR	NR
Cadmium	mg/L	0.00257 J	0.00510	0.000548 J	0.0118	0.0102	0.0117	0.0101	0.0113	NR	NR	NR	NR
Chromium	mg/L	0.00262 U	0.00608	0.0409	0.0100 J	0.00968	0.0156	0.00792	0.0132	NR	NR	NR	NR
Cobalt	mg/L	0.000579 J	0.0871	0.00751	0.220	0.186	0.216	0.195	0.215	NR	NR	NR	NR
Fluoride	mg/L	0.0360 U	0.439 JH	0.330	1.53	1.26	1.37 JH	1.30	1.32	NR	NR	NR	NR
Lead	mg/L	0.000758 U	0.000152 U	0.000152 U	0.000758 U	0.000164 J	0.000220 J	0.000261 J	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.0123 J	0.119	0.00238 U	0.326	0.340	0.371	0.372	0.379	NR	NR	NR	NR
Mercury	mg/L	0.000834	0.000289	0.00143	0.00240	0.00244	0.00160	0.00113	0.00226	NR	NR	NR	NR
Molybdenum	mg/L	0.00397 J	0.00261	0.0686	0.00183 J	0.000704 J	0.000791 J	0.00151 J	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.0334	0.0448	0.0313	0.0673	0.0616	0.0697	0.0633	0.0663	NR	NR	NR	NR
Thallium	mg/L	0.00166 U	0.000487 J	0.000332 U	0.00166 U	0.000876 J	0.00114 J	0.000889 J	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	0.0888 ± 0.151	1.12 ± 0.342	0.453 ± 0.276	4.85 ± 0.656	4.02 ± 0.608	4.32 ± 0.667	6.28 ± 0.845	3.6 ± 0.600	NR	NR	NR	NR
Radium-228	pCi/L	2.14 ± 1.02	2.17 ± 0.979	0.166 ± 0.861 U	4.28 ± 1.19	3.44 ± 1.04	3.95 ± 1.79	2.63 ± 0.928	3.3 ± 1.33	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.

NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-61 Downgradient											
Sample Date		12/7/16	2/23/17	3/29/17	5/3/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/31/18	4/10/19	10/22/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Apr 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	1.07	1.29	1.15	1.18	0.960	1.01 JH	0.994	0.997	1.09	3.25	2.72	2.90
Calcium	mg/L	134	95.9	155	113	115	107 JH	105	135	171	197 D	176	168 D
Chloride	mg/L	198	158	162	168	193	190 JH	218 D	210	285	213	253	248
Fluoride	mg/L	0.393	0.503	0.522	0.643 JH	0.459 JH	0.479 JH	0.0960 U	0.0360 U	0.406 J	0.430 J	0.403 J	0.480 J
Sulfate	mg/L	401 D	377 JD	382 D	388	408 D	390 JHD	385 D	401	562	548	619	548 D
pH - Field Collected	SU	6.72	6.51	6.48	6.68	6.53	6.55	7.40	6.27	6.42	6.38	6.52	5.61
Total dissolved solids	mg/L	1400	1180	1190	1260	1430	1290 JH	1170	1280	1620	514	1650	1790
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.00120 U	0.000240 U	0.000240 U	0.00120 U	0.000240 U	0.000240 U	0.000240 U	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.00123 U	0.000768 J	0.000709 J	0.00123 U	0.000563 J	0.000622 J	0.000569 J	0.000246 U	NR	NR	NR	NR
Barium	mg/L	0.0364	0.0186	0.0173	0.0178 J	0.0148	0.0167	0.0153	0.0162	NR	NR	NR	NR
Beryllium	mg/L	0.000654 U	0.000131 U	0.000131 U	0.000654 U	0.000131 U	0.000131 U	0.000131 U	0.000131 U	NR	NR	NR	NR
Cadmium	mg/L	0.000734 U	0.000147 U	0.000147 U	0.000734 U	0.000147 U	0.000147 U	0.000147 U	0.000147 U	NR	NR	NR	NR
Chromium	mg/L	0.00262 U	0.000911 J	0.000525 U	0.00262 U	0.000525 U	0.000604 J	0.000808 J	0.000525 U	NR	NR	NR	NR
Cobalt	mg/L	0.000719 J	0.000725 J	0.000769 J	0.000779 J	0.000805 J	0.000765 J	0.000855 J	0.0000699 U	NR	NR	NR	NR
Fluoride	mg/L	0.393	0.503	0.522	0.643 JH	0.459 JH	0.479 JH	0.0960 U	0.0360 U	NR	NR	NR	NR
Lead	mg/L	0.000758 U	0.000152 U	0.000152 U	0.000758 U	0.000152 U	0.000152 U	0.000152 U	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.000476 U	0.0158 J	0.00238 U	0.0120 J	0.0342	0.0336	0.0443	0.0335	NR	NR	NR	NR
Mercury	mg/L	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	NR	NR	NR	NR
Molybdenum	mg/L	0.00165 J	0.00129 J	0.000984 J	0.00128 U	0.000776 J	0.000742 J	0.000712 J	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.00227 U	0.00123 J	0.00123 J	0.00227 U	0.00185 J	0.00154 J	0.00172 J	0.000454 U	NR	NR	NR	NR
Thallium	mg/L	0.00166 U	0.000332 U	0.000332 U	0.00166 U	0.000332 U	0.000332 U	0.000332 U	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	1.15 ± 0.429	0.723 ± 0.306	0.256 ± 0.237 U	0.237 ± 0.193	0.398 ± 0.239	0.511 ± 0.223	0.821 ± 0.324	0.485 ± 0.212	NR	NR	NR	NR
Radium-228	pCi/L	2.79 ± 1.44	0.358 ± 1.06	0.761 ± 0.688 U	-0.064 ± 0.607	2.03 ± 0.997	0.491 ± 0.813	0.247 ± 0.710	1.64 ± 1.08	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.

NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

TABLE 3
Groundwater Analytical Results Summary
CPS Energy - Calaveras Power Station
Evaporation Pond

		JKS-62 Downgradient											
Sample Date		12/8/16	2/23/17	3/29/17	5/4/17	6/21/17	7/26/17	8/30/17	10/11/17	4/5/18	10/30/18	4/10/19	10/23/19
Task		Event 1 Dec 2016	Event 2 Feb 2017	Event 3 Mar 2017	Event 4 May 2017	Event 5 Jun 2017	Event 6 Jul 2017	Event 7 Aug 2017	Event 8 Oct 2017	Event 9 Apr 2018	Event 10 Oct 2018	Event 11 Apr 2019	Event 12 Oct 2019
Constituents	Unit												
Appendix III - Detection Monitoring													
Boron	mg/L	0.549	0.481	0.597	0.601	0.501	0.485 JH	0.485	0.549	0.522	0.559	0.612	0.528
Calcium	mg/L	155	152	220	156	150	134 JH	150	158	160	161 D	205 D	151 D
Chloride	mg/L	257 D	279 DX	279 D	278	291 D	260 JHD	281 D	241	312	279	336	276
Fluoride	mg/L	0.246	0.362 JH	0.418	0.388	0.366 JH	0.342 JH	0.233 JH	0.0360 U	0.353 J	0.309 J	0.356 J	0.380 J
Sulfate	mg/L	190	187	193	188	184	181 JH	188 D	175	200	183	191	183
pH - Field Collected	SU	6.79	6.67	6.63	6.71	6.68	6.82	7.51	6.52	6.72	6.58	6.29	5.43
Total dissolved solids	mg/L	1120	1170	1140	1100	1080	976 JH	1080	1080	1110	956	1190	1160
Appendix IV - Assessment Monitoring													
Antimony	mg/L	0.000240 U	0.000240 U	0.000240 U	0.00120 U	0.000240 U	0.000240 U	0.000240 U	0.000240 U	NR	NR	NR	NR
Arsenic	mg/L	0.000684 J	0.000293 J	0.000246 U	0.00123 U	0.000254 J	0.000246 U	0.000246 U	0.000246 U	NR	NR	NR	NR
Barium	mg/L	0.0825	0.0786	0.0813	0.0747	0.0734	0.0737	0.0708	0.0793	NR	NR	NR	NR
Beryllium	mg/L	0.000131 U	0.000131 U	0.000131 U	0.000654 U	0.000131 U	0.000131 U	0.000131 U	0.000131 U	NR	NR	NR	NR
Cadmium	mg/L	0.000147 U	0.000147 U	0.000147 U	0.000734 U	0.000147 U	0.000147 U	0.000147 U	0.000147 U	NR	NR	NR	NR
Chromium	mg/L	0.00186 J	0.00109 J	0.000525 U	0.00262 U	0.000551 J	0.000691 J	0.00107 J	0.000525 U	NR	NR	NR	NR
Cobalt	mg/L	0.00110 J	0.000198 J	0.000744 J	0.000350 U	0.000278 J	0.000211 J	0.0000699 U	0.0000699 U	NR	NR	NR	NR
Fluoride	mg/L	0.246	0.362 JH	0.418	0.388	0.366 JH	0.342 JH	0.233 JH	0.0360 U	NR	NR	NR	NR
Lead	mg/L	0.000588 J	0.000152 U	0.000152 U	0.000758 U	0.000154 J	0.000152 U	0.000152 U	0.000152 U	NR	NR	NR	NR
Lithium	mg/L	0.000476 U	0.0129 J	0.00238 U	0.00134 J	0.0353	0.0305	0.0457	0.0263	NR	NR	NR	NR
Mercury	mg/L	0.0000540 J	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	0.0000263 U	NR	NR	NR	NR
Molybdenum	mg/L	0.000414 J	0.000259 J	0.000255 U	0.00128 U	0.000255 U	0.000255 U	0.000255 U	0.000255 U	NR	NR	NR	NR
Selenium	mg/L	0.222	0.192	0.196	0.195	0.185	0.181	0.191	0.208	NR	NR	NR	NR
Thallium	mg/L	0.000332 U	0.000332 U	0.000332 U	0.00166 U	0.000332 U	0.000332 U	0.000332 U	0.000332 U	NR	NR	NR	NR
Radium-226	pCi/L	0.485 ± 0.229	0.402 ± 0.220	0.665 ± 0.321	0.0997 ± 0.153	0.425 ± 0.233	0.399 ± 0.220	2.02 ± 0.489	0.669 ± 0.279	NR	NR	NR	NR
Radium-228	pCi/L	2.15 ± 1.38	1.53 ± 1.28 U	0.305 ± 1.10 U	-0.138 ± 0.656	0.66 ± 0.760	1.07 ± 0.949	0.673 ± 0.821	0.371 ± 0.631	NR	NR	NR	NR

NOTES:

(A) JKS-63 plugged and abandoned and replaced with JKS-63R on 5/2/19. Sample events 1 through 10 collected from JKS-63 and thereafter from JKS-63R.

(1) Sample not collected due to the well going dry during sampling activities.

(2) Sample not collected due to blockage in the well casing.

mg/L: Milligrams per Liter.

SU: Standard Units.

pCi/L: Picocuries per Liter.

-- : Laboratory did not analyze sample for indicated constituent.

B: Target analyte or common lab contaminant was identified in the method blank.

D: Sample diluted due to targets detected over highest point of calibration curve or due to matrix interference.

J: Analyte detected above method (sample) detection limit but below method quantitation limit.

H: Bias in sample result likely to be high.






NR: Analysis of this constituent not required for detection monitoring.

U: Analyte not detected at laboratory reporting limit (Sample Detection Limit).

X: Matrix Spike/Matrix Spike Duplicate recoveries were found to be outside of the laboratory control limits.

Figures

Legend

-  Background Monitor Well
-  Downgradient Monitor Well
-  Groundwater Elevation Observation Well
-  Plugged and Abandoned Monitor Well
-  CCR Unit



Environmental Resources Management









FIGURE 1
CCR WELL NETWORK LOCATION MAP
CPS Energy - Calaveras Power Station
San Antonio, Texas




DESIGN: WZ	DRAWN: EFC	CHKD.: WZ
DATE: 1/17/2020	SCALE: AS SHOWN	REVISION: 0

\\houston011\Data\Houston\Projects\0503422 CPS Energy Calaveras 2019 CCR Tasks\WZ\GIS_CAD\MXD\2019gwmonr\fig1_0503422_CPSCalv_WellLocs.mxd

Legend

-  Background Monitor Well
-  Downgradient Monitor Well
-  Groundwater Elevation Observation Well
-  Plugged and Abandoned Monitor Well
-  CCR Unit
-  Potentiometric Surface Contour Line (Feet, Mean Sea Level)
-  Groundwater Flow Direction
-  Potentiometric Surface Elevation (Feet, Mean Sea Level)



Environmental Resources Management

DESIGN:	NH	DRAWN:	EFC	CHKD.:	WZ
DATE:	1/15/2020	SCALE:	AS SHOWN	REVISION:	0

\\ushouf011\Data\Houston\Projects\0503422 CPS Energy Calaveras 2019 CCR Tasks\WZ\GIS_CAD\IMXD\2019\gwmon\fig2_0503422_CPSCalv_Evap_oct2019pmap.mxd

FIGURE 2
POTENTIOMETRIC SURFACE MAP -
OCTOBER 2019
Evaporation Pond CCR Unit
CPS Energy - Calaveras Power Station
San Antonio, Texas



Laboratory Data Packages

Appendix A

(Data Packages Available Upon Request)

Statistical Analysis Tables and Figures

Appendix B

APPENDIX B - TABLE 1
Kruskal-Wallis Test Comparisons of Upgradient Wells
Calaveras Power Station
Evaporation Pond

Analyte	N	Num Detects	Percent Detect	DF	KW Statistic	p-value	Conclusion	UPL Type
Boron	33	33	100.00%	2	9.91	0.00706	Significant Difference	Intrawell
Calcium	34	34	100.00%	2	29.1	<0.001	Significant Difference	Intrawell
Chloride	34	34	100.00%	2	29.3	<0.001	Significant Difference	Intrawell
Fluoride	34	23	67.65%	2	1.38	0.503	No Significant Difference	Interwell
pH	35	35	100.00%	2	13.1	0.00145	Significant Difference	Intrawell
Sulfate	34	33	97.06%	2	19.7	<0.001	Significant Difference	Intrawell
Total dissolved solids	34	34	100.00%	2	29.3	<0.001	Significant Difference	Intrawell

NOTES:

Non-detects were substituted with a value of half the detection limit for calculations

N: number of data points

DF: degrees of freedom

statistic: Kruskal Wallis test statistic

p-value: P-values below 0.05 indicate that the median concentrations in the upgradient wells are significantly different from each other and the upgradient wells should not be pooled.

p-value: P-values equal or above 0.05 indicate that the median concentrations in the upgradient wells are not significantly different from each other and the upgradient wells can be pooled.

APPENDIX B - TABLE 2
Descriptive Statistics for Upgradient Wells
Calaveras Power Station
Evaporation Pond

Analyte	Well	Units	N	Num Detects	Percent Detect	Min ND	Max ND	Min Detect	Median	Mean	Max Detect	SD	CV	Distribution
Boron	JKS-47	mg/L	12	12	100.00%			0.59	0.82	0.823	1.05	0.123	0.149296105	Normal
Boron	JKS-63	mg/L	9	9	100.00%			0.8	1.06	1.16	2.03	0.365	0.314253394	Lognormal
Boron	JKS-64	mg/L	12	12	100.00%			0.747	0.837	0.869	1.14	0.102	0.117394176	NDD
Calcium	JKS-47	mg/L	12	12	100.00%			26.2	62.4	70.7	168	40.4	0.572091587	Lognormal
Calcium	JKS-63	mg/L	10	10	100.00%			174	836	736	1060	299	0.406508671	NDD
Calcium	JKS-64	mg/L	12	12	100.00%			20.6	23.9	24	31.4	2.7	0.112710312	NDD
Chloride	JKS-47	mg/L	12	12	100.00%			53.9	160	162	279	64.9	0.400327364	Normal
Chloride	JKS-63	mg/L	10	10	100.00%			1160	1540	1650	2360	442	0.267920321	Normal
Chloride	JKS-64	mg/L	12	12	100.00%			9.63	12.1	13	17.7	2.47	0.189995473	Normal
Fluoride	Pooled	mg/L	34	23	67.65%	0.018	0.18	0.0573	0.156	0.158	0.382	0.121	0.765413882	NDD
pH	JKS-47	SU	13	13	100.00%			4.58	5.83	5.72	6	0.372	0.065032378	NDD
pH	JKS-63	SU	10	10	100.00%			4.76	5.64	5.59	5.88	0.329	0.058918156	NDD
pH	JKS-64	SU	12	12	100.00%			4.82	6.17	6.03	6.46	0.449	0.074430618	NDD
Sulfate	JKS-47	mg/L	12	12	100.00%			171	264	264	369	56.2	0.212664879	Normal
Sulfate	JKS-63	mg/L	10	9	90.00%	0.023	0.023	1750	1860	1700	2110	605	0.356166285	NDD
Sulfate	JKS-64	mg/L	12	12	100.00%			164	178	180	196	10.7	0.059743519	Normal
Total dissolved solids	JKS-47	mg/L	12	12	100.00%			665	858	896	1240	187	0.208882243	Normal
Total dissolved solids	JKS-63	mg/L	10	10	100.00%			4760	5210	5450	6660	646	0.118498469	Normal
Total dissolved solids	JKS-64	mg/L	12	12	100.00%			463	574	562	611	39.1	0.069461679	Normal

NOTES:

Non-detects were substituted with a value of half the detection limit for calculations

Well = Pooled, indicates that the summary statistics were produced for the pooled upgradient wells based on the Kruskal-Wallis test (Table 1).

SU: Standard units

N: number of data points

ND: Non-detect

SD: Standard Deviation

CV: Coefficient of Variation (standard deviation divided by the mean)

NDD: No Discernible Distribution

APPENDIX B - TABLE 3
Potential Outliers in Upgradient Wells
Calaveras Power Station
Evaporation Pond

Well	Sample	Date	Analyte	Units	Detect	Concentration	UPL type	Distribution	Statistical Outlier	Visual Outlier	Normal Outlier	Log Statistical Outlier	Log Visual Outlier	Lognormal Outlier	Statistical and Visual Outlier
JKS-47	JKS 47565343-007	10/11/2017	Boron	mg/L	TRUE	1.02	Intrawell	Normal		X			X		
JKS-47	JKS-47002	10/23/2019	Boron	mg/L	TRUE	1.05	Intrawell	Normal		X			X		
JKS-63	63R001	8/20/2019	Boron	mg/L	TRUE	2.03	Intrawell	Lognormal	X	X	X		X		
JKS-64	JKS-64549681-009	3/29/2017	Boron	mg/L	TRUE	1.14	Intrawell	NDD	X	X	X	X	X	X	0
JKS-47	JKS-47549681-004	3/29/2017	Calcium	mg/L	TRUE	168	Intrawell	Lognormal	X	X	X		X		
JKS-47	JKS47620699-005	4/10/2019	Calcium	mg/L	TRUE	128	Intrawell	Lognormal		X			X		
JKS-64	JKS-64549681-009	3/29/2017	Calcium	mg/L	TRUE	31.4	Intrawell	NDD	X	X	X	X	X	X	0
JKS-47	JKS-47-WG-20170223	2/23/2017	pH	SU	TRUE	5.42	Intrawell	NDD	X	X	X	X	X	X	0
JKS-47	JKS-47-WG-20191023-02	10/23/2019	pH	SU	TRUE	4.58	Intrawell	NDD	X	X	X	X	X	X	0
JKS-63	JKS-63-WG-20170222	2/22/2017	pH	SU	TRUE	5.35	Intrawell	NDD		X			X		
JKS-63	JKS-63R-WG-20191023-02	10/23/2019	pH	SU	TRUE	4.76	Intrawell	NDD	X	X	X	X	X	X	0
JKS-64	JKS-64-WG-20170223	2/23/2017	pH	SU	TRUE	5.5	Intrawell	NDD	X	X	X	X	X	X	0
JKS-64	JKS-64-WG-20191023-02	10/23/2019	pH	SU	TRUE	4.82	Intrawell	NDD	X	X	X	X	X	X	0
JKS-47	JKS47620699-005	4/10/2019	Sulfate	mg/L	TRUE	347	Intrawell	Normal		X					
JKS-63	WELL 63581537-002	4/5/2018	Sulfate	mg/L	TRUE	2110	Intrawell	NDD		X			X		
JKS-63	JKS 63558516-006	7/26/2017	Total dissolved solids	mg/L	TRUE	6410	Intrawell	Normal		X					

NOTES:

NDD: No Discernible Distribution

SU: Standard units

Outlier tests were performed on detected data only.

Statistical outliers were determined using a Dixon's test for N < 25 and with Rosner's test for N > 25.

Visual outliers were identified if they fall above the confidence envelope on the QQ plot.

Data points were considered potential outliers if they were both statistical and visual outliers.

NDD wells had data points considered as potential outliers if they were either a normal or lognormal outlier.

[Blank] data distribution indicates that the well data did not have enough detected data points for outlier analysis.

Lognormally distributed data was first log-transformed before visual and statistical outlier tests were performed.

Normal data distribution indicates that the well data was directly used for statistical and visual outlier tests.

NDD indicates that both the untransformed and transformed data were examined with statistical and visual outlier tests.

'0' indicates that the data point was a statistical and visual outlier but was retained after review by the hydrogeologist.

APPENDIX B - TABLE 4
Mann Kendall Test for Trends in Upgradient Wells
Calaveras Power Station
Evaporation Pond

Analyte	UPL Type	Well	N	Num Detects	Percent Detect	p-value	tau	Conclusion
Boron	Intrawell	JKS-47	12	12	100.00%	0.737	0.0909	Stable, No Trend
Boron	Intrawell	JKS-63	9	9	100.00%	0.119	0.444	Stable, No Trend
Boron	Intrawell	JKS-64	12	12	100.00%	0.011	-0.565	Decreasing Trend
Calcium	Intrawell	JKS-47	12	12	100.00%	0.841	0.0606	Stable, No Trend
Calcium	Intrawell	JKS-63	10	10	100.00%	1	0.0222	Stable, No Trend
Calcium	Intrawell	JKS-64	12	12	100.00%	0.89	-0.0308	Stable, No Trend
Chloride	Intrawell	JKS-47	12	12	100.00%	1	0	Stable, No Trend
Chloride	Intrawell	JKS-63	10	10	100.00%	0.00915	0.644	Increasing Trend
Chloride	Intrawell	JKS-64	12	12	100.00%	0.149	0.321	Stable, No Trend
Fluoride	Interwell	JKS-47, JKS-63, JKS-64	34	23	67.65%	0.381	-0.109	Stable, No Trend
pH	Intrawell	JKS-47	13	13	100.00%	0.582	0.116	Stable, No Trend
pH	Intrawell	JKS-63	10	10	100.00%	1	0.0222	Stable, No Trend
pH	Intrawell	JKS-64	12	12	100.00%	0.0331	-0.473	Decreasing Trend
Sulfate	Intrawell	JKS-47	12	12	100.00%	0.459	-0.182	Stable, No Trend
Sulfate	Intrawell	JKS-63	10	9	90.00%	1	0	Stable, No Trend
Sulfate	Intrawell	JKS-64	12	12	100.00%	0.192	0.29	Stable, No Trend
Total dissolved solids	Intrawell	JKS-47	12	12	100.00%	0.116	-0.364	Stable, No Trend
Total dissolved solids	Intrawell	JKS-63	10	10	100.00%	0.381	0.244	Stable, No Trend
Total dissolved solids	Intrawell	JKS-64	12	12	100.00%	0.0629	-0.424	Stable, No Trend

NOTES:

Non-detects were substituted with a value of zero for trend calculations

N: number of data points

tau: Kendall's tau statistic

p-value: A two-sided p-value describing the probability of the H0 being true ($\alpha=0.05$)

Trend tests were performed on all upgradient data, only if the dataset met the minimum data quality criteria (ERM 2017).

APPENDIX B - TABLE 5
Calculated UPLs for Upgradient Datasets
Calaveras Power Station
Evaporation Pond

Analyte	UPL Type	Trend	Well	N	Num Detects	Percent Detects	LPL	UPL	Units	ND Adjustment	Transformation	Alpha	Method	Final LPL	Final UPL
Boron	Intrawell	Stable, No Trend	JKS-47	12	12	1		1.04	mg/L	None	No	0.00584	Param Intra 1 of 2		
Boron	Intrawell	Stable, No Trend	JKS-63	9	9	1		1.88	mg/L	None	No	0.00584	Param Intra 1 of 2		X
Boron	Intrawell	Decreasing Trend	JKS-64	12	12	1		0.973	mg/L	None	No	0.00584	NP Detrended UPL		
Calcium	Intrawell	Stable, No Trend	JKS-47	12	12	1		143	mg/L	None	No	0.00584	Param Intra 1 of 2		
Calcium	Intrawell	Stable, No Trend	JKS-63	10	10	1		1300	mg/L	None	No	0.00584	Param Intra 1 of 2		X
Calcium	Intrawell	Stable, No Trend	JKS-64	12	12	1		28.8	mg/L	None	ln(x)	0.00584	Param Intra 1 of 2		
Chloride	Intrawell	Stable, No Trend	JKS-47	12	12	1		278	mg/L	None	No	0.00584	Param Intra 1 of 2		
Chloride	Intrawell	Increasing Trend	JKS-63	10	10	1		2780	mg/L	None	No	0.00584	NP Detrended UPL		X
Chloride	Intrawell	Stable, No Trend	JKS-64	12	12	1		17.4	mg/L	None	No	0.00584	Param Intra 1 of 2		
Fluoride	Interwell	Stable, No Trend	JKS-47, JKS-63, JKS-64	34	23	0.6764706		0.382	mg/L	None	No	0.00159	NP Inter (normality) 1 of 2		X
pH	Intrawell	Stable, No Trend	JKS-47	13	13	1	4.58	6	SU	None	No	0.0198	NP Intra (normality) 1 of 2	X	
pH	Intrawell	Stable, No Trend	JKS-63	10	10	1	4.76	5.88	SU	None	No	0.0303	NP Intra (normality) 1 of 2		
pH	Intrawell	Decreasing Trend	JKS-64	12	12	1	4.93	6.47	SU	None	No	0.022	NP Detrended UPL		X
Sulfate	Intrawell	Stable, No Trend	JKS-47	12	12	1		365	mg/L	None	No	0.00584	Param Intra 1 of 2		
Sulfate	Intrawell	Stable, No Trend	JKS-63	10	9	0.9		2110	mg/L	None	No	0.0152	NP Intra (normality) 1 of 2		X
Sulfate	Intrawell	Stable, No Trend	JKS-64	12	12	1		199	mg/L	None	No	0.00584	Param Intra 1 of 2		
Total dissolved solids	Intrawell	Stable, No Trend	JKS-47	12	12	1		1230	mg/L	None	No	0.00584	Param Intra 1 of 2		
Total dissolved solids	Intrawell	Stable, No Trend	JKS-63	10	10	1		6660	mg/L	None	No	0.00584	Param Intra 1 of 2		X
Total dissolved solids	Intrawell	Stable, No Trend	JKS-64	12	12	1		632	mg/L	None	No	0.00584	Param Intra 1 of 2		

NOTES:

Non-detects (ND) were substituted with a value of half the detection limit for calculations

UPL: upper prediction limit

LPL: Lower prediction limit. These were only calculated for pH

UPLs were constructed with a site wide false positive rate of 0.1 and a 1 of 2 retesting.

UPLs were calculated using Sanitas Software.

SU: Standard units

NP: non parametric

Intra: indicates an intrawell UPL was used

Inter: indicates an interwell UPL was used

In the case where multiple UPLs were calculated for an analyte, the maximum UPL was used as the final UPL.

In the case where multiple LPLs were calculated for an pH the minimum LPL was used as the final LPL.

APPENDIX B - TABLE 6
Comparisons of Downgradient Wells to UPLs
Calaveras Power Station
Evaporation Pond

Analyte	Well	LPL	UPL	Units	Recent Date	Observation	Qualifier	Obs > UPL	Notes	Mann Kendall p-value	Mann Kendall tau
Boron	JKS-36		1.88	mg/L	43760	0.632					
Boron	JKS-61		1.88	mg/L	43760	2.9		X	Trend Test: Stable, No Trend	0.204	0.282
Boron	JKS-62		1.88	mg/L	43761	0.528					
Calcium	JKS-36		1300	mg/L	43760	265					
Calcium	JKS-61		1300	mg/L	43760	168					
Calcium	JKS-62		1300	mg/L	43761	151					
Chloride	JKS-36		2780	mg/L	43760	274					
Chloride	JKS-61		2780	mg/L	43760	248					
Chloride	JKS-62		2780	mg/L	43761	276					
Fluoride	JKS-36		0.382	mg/L	43760	1.41		X	Trend Test: Increasing Trend	0.021	0.515
Fluoride	JKS-61		0.382	mg/L	43760	0.48		X	Trend Test: Stable, No Trend	0.45	-0.168
Fluoride	JKS-62		0.382	mg/L	43761	0.38					
pH	JKS-36	4.58	6.47	SU	43760	3.66		X	Trend Test: Decreasing Trend	0.021	-0.515
pH	JKS-61	4.58	6.47	SU	43760	5.61					
pH	JKS-62	4.58	6.47	SU	43761	5.43					
Sulfate	JKS-36		2110	mg/L	43760	756					
Sulfate	JKS-61		2110	mg/L	43760	548					
Sulfate	JKS-62		2110	mg/L	43761	183					
Total dissolved solids	JKS-36		6660	mg/L	43760	1600					
Total dissolved solids	JKS-61		6660	mg/L	43760	1790					
Total dissolved solids	JKS-62		6660	mg/L	43761	1160					

NOTES:

Non-detects were substituted with a value of zero for trend calculations

UPL: Upper Prediction Limit

ND: Not detected

SU: Standard units





tau: Kendall's tau statistic

Obs > UPL: Exceed 'X' indicates that the most recent observed value is higher than the UPL (or out of range of the LPL and UPL in the case of pH.)




Obs > UPL: Exceed 'X0' indicates that the two most recent values are higher than the UPL, but the upgradient well is 100% ND.

Obs > UPL: Exceed '0' indicated that the most recent observed value is higher than the UPL, but is not scored as an SSI due to Double Quantification Rule (ERM 2017).



Appendix B – Figure 1
Unit: Evaporation Pond
Boxplots of Upgradient Wells





Appendix B – Figure 1
Unit: Evaporation Pond
Boxplots of Upgradient Wells




Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells







Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells




Intentionally left blank,
not Normal/NDD distribution.




Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells



Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells




Intentionally left blank,
not Lognormal/NDD distribution.





Intentionally left blank,
not Lognormal/NDD distribution.





Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells






Intentionally left blank,
not Lognormal/NDD distribution.



Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells






Appendix B – Figure 2 Unit: Evaporation Pond QQ Plots of Upgradient Wells




Intentionally left blank,
not Lognormal/NDD distribution.

Appendix B – Figure 2 Unit: Evaporation Pond QQ Plots of Upgradient Wells




Intentionally left blank,
not Lognormal/NDD distribution.

Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells




Intentionally left blank,
not Lognormal/NDD distribution.





Intentionally left blank,
not Lognormal/NDD distribution.

Appendix B – Figure 2
Unit: Evaporation Pond
QQ Plots of Upgradient Wells




Intentionally left blank,
not Lognormal/NDD distribution.

Appendix B – Figure 3
Unit: Evaporation Pond
Timeseries of Upgradient Wells




Appendix B – Figure 3
Unit: Evaporation Pond
Timeseries of Upgradient Wells



Chemical: Chloride
 Significant Difference (Intrawell Analysis)



Chemical: Fluoride
 No Significant Difference (Interwell Analysis)




Appendix B – Figure 3
Unit: Evaporation Pond
Timeseries of Upgradient Wells




Appendix B – Figure 3
Unit: Evaporation Pond
Timeseries of Upgradient Wells

Chemical: Total dissolved solids
Significant Difference (Intrawell Analysis)




Appendix B – Figure 4
Unit: Evaporation Pond
Trend Analysis of Downgradient Wells with Exceedances



Chemical: Boron
 Well: JKS-61



Chemical: Fluoride
 Well: JKS-36



Appendix B – Figure 4
Unit: Evaporation Pond
Trend Analysis of Downgradient Wells with Exceedances



**April 2019 Groundwater Sampling Event –
Calaveras Power Station CCR Units**

Appendix C

July 11, 2019

Mr. Michael Malone
CPS Energy
145 Navarro Street
San Antonio, Texas 78205

Project No. 0503422

**Environmental
Resources
Management**

CityCentre Four
840 West Sam Houston Pkwy N.
Suite 600
Houston, Texas 77024
(281) 600-1000
(281) 600-1001 (Fax)

Subject: April 2019 Groundwater Sampling Event
Calaveras Power Station CCR Units
San Antonio, Texas


Dear Mr. Malone:

Introduction

Title 40, Code of Federal Regulations, Part 257 (40 CFR §257) (a.k.a. the Coal Combustion Residual (CCR) Rule) was published in the Federal Register in April 2015 and became effective in October 2015. One of the many requirements of the CCR Rule was for CPS Energy to determine if there are impacts to groundwater from the surface impoundments [Evaporation Pond (EP), Bottom Ash Ponds (BAPs), and Sludge Recycling Holding (SRH) Pond] and the landfill [Fly Ash Landfill (FAL)] that contain CCR at the Calaveras Power Station.

In the initial *Annual Groundwater Monitoring and Corrective Action Report* for each CCR unit, the downgradient monitoring well results from the October 2017 sampling event were compared to Upper Prediction Limits (UPLs) and Lower Prediction Limits (LPLs). UPLs and LPLs were calculated in the respective *Annual Groundwater Monitoring and Corrective Action Reports* for the purpose of determining a potential statistically significant increase (SSI) over background levels. In the second *Annual Groundwater Monitoring and Corrective Action Report* for each CCR unit, the downgradient monitoring well results from the October 2018 sampling event were compared to updated UPLs and LPLs. These updated UPLs and LPLs were recalculated in the respective *Annual Groundwater Monitoring and Corrective Action Reports* using the additional 2018 data. The evaluations of the April 2019 groundwater sample results indicated a potential SSI for a limited number of constituents from the EP, FAL, BAPs, and SRH Pond.

According to the CCR Rule [§257.94(e)], if the owner or operator of a CCR unit determines there is a SSI over background levels for one or more Appendix III constituents, the owner or operator may demonstrate that a source other than the CCR unit caused the SSI over background levels or that the SSI resulted from error in sampling, analysis, statistical evaluation or natural variation in



groundwater quality. The CCR Rule also indicates that the owner or operator must complete the written demonstration within 90 days of detecting a SSI over the background levels. If a successful demonstration is completed within the 90-day period, the owner or operator may continue with a detection monitoring program.

To address the potential SSIs identified in the initial *Annual Groundwater Monitoring and Corrective Action Reports*, CPS Energy prepared *Written Demonstration – Responses to Potential Statistically Significant Increases* (dated April 4, 2018). To address the potential SSIs identified in the second *Annual Groundwater Monitoring and Corrective Action Reports*, CPS Energy prepared *Written Demonstration – Responses to Potential Statistically Significant Increases* (dated February 27, 2019). Based on the evidence provided in the *Written Demonstrations*, no SSIs over background levels were determined for any of the CPS Energy CCR units (EP, FAL, BAPs, and SRH Pond) and therefore, CPS Energy continued with a detection monitoring program that would include semiannual sampling.

Sampling Event Summary

The first semiannual groundwater sampling event for 2019 was conducted on April 9 through April 10. The sampling event included the collection of water level measurements and groundwater samples from all the background and downgradient monitoring wells in the CCR monitoring program. The groundwater samples were analyzed for Appendix III constituents.

For each CCR unit, the downgradient monitoring well results from the April 2019 sampling event were compared to the updated UPLs and LPLs recalculated in their respective second *Annual Groundwater Monitoring and Corrective Action Report*. The April 2019 groundwater sample results for the downgradient monitoring wells in each CCR unit are summarized in Attachment 1.

Although the evaluations of the April 2019 groundwater sample results indicated a potential SSI for a limited number of constituents, with the exception of calcium in JKS-60 associated with the FAL and fluoride in JKS-52 associated with the SRH Pond, the constituents associated with the potential SSIs are the same constituents, detected at similar concentrations, that were previously identified in one or both of the *Written Demonstrations*. The evaluations of the April 2019 groundwater sample results with potential SSIs are summarized below.

EP – The constituents associated with potential SSIs include boron in JKS-61; fluoride in JKS-36, JKS-61, and JKS-62; and pH in JKS-36. As previously presented in the *Written Demonstrations*, the concentrations of boron, fluoride, and pH appear to reflect natural variation in groundwater quality in the vicinity of the CCR unit. The reported April 2019 concentrations were within the range of naturally occurring concentrations identified in the *Written Demonstrations*.

FAL – The constituents associated with potential SSIs include calcium in JKS-33 and JKS-60; chloride in JKS-33; and pH in JKS-31 and JKS-46. As previously presented in the *Written Demonstrations*, the concentrations of calcium, chloride, and pH appear to reflect natural variation in groundwater quality in the vicinity of the CCR unit. The reported April 2019 concentrations were within the range of naturally occurring concentrations identified in the *Written Demonstrations*.

BAPs – The constituents associated with potential SSIs include boron in JKS-50R and JKS-56 and fluoride in JKS-48. As previously presented in the *Written Demonstrations*, the concentrations of boron and fluoride appear to reflect natural variation in groundwater quality in the vicinity of the CCR unit. The reported April 2019 concentrations were within the range of naturally occurring concentrations identified in the *Written Demonstrations*.

SRH Pond – The constituent associated with a potential SSI is fluoride in JKS-52. Although a potential SSI of fluoride was not previously presented in the *Written Demonstrations*, the concentrations of fluoride appear to reflect natural variation in groundwater quality in the vicinity of the CCR unit and the reported April 2019 concentration is within the range of naturally occurring concentrations identified in the *Annual Groundwater Monitoring and Corrective Action Reports*. Also note that although the normal groundwater sample collected from JKS-52 indicated a potential SSI of fluoride, a field duplicate sample collected from JKS-52 after the normal sample did not indicate a potential SSI.

Conclusions

Based on the April 2019 groundwater sample results and the evidence provided in one or both of the *Written Demonstrations*, no SSIs over background levels have been determined for any of the CPS Energy CCR units (EP, FAL, BAPs, and SRH Pond) and therefore, CPS Energy should continue with a detection monitoring program. The second semiannual sampling event should be performed in October 2019.

We appreciate the opportunity to work with you on this project. Please contact me if you should have any questions.

Sincerely,

Environmental Resources Management



Wally Zverina
Principal Consultant

Attachment 1
April 2019 Groundwater Sample Results

July 2019
Project No. 0503422
CPS Energy

April 2019 Groundwater Sample Results
CCR Unit: Evaporation Pond
CPS Energy Calaveras Power Station
San Antonio, TX

				CCR Unit	EP	EP	EP	EP
				Well Designation	Downgradient	Downgradient	Downgradient	Downgradient
				Well ID	JKS-36	JKS-61	JKS-62	JKS-62
				Sample Date	4/9/2019	4/9/2019	4/9/2019	4/9/2019
				Sample Type Code	N	N	N	FD
Chemical	Units	2017-2018 LPL - EP	2017-2018 UPL - EP					
Boron	mg/L	--	1.33		0.663	2.72	0.612	0.554 X
Calcium	mg/L	--	1310		315 D	176	205 D	173 X
Chloride	mg/L	--	2120		285	253	336	329
Fluoride	mg/L	--	0.271		1.45	0.403 J	0.356 J	0.349 J
pH, Field	SU	5.36	6.63		3.71	6.52	6.29	6.29
Sulfate	mg/L	--	2110		697	619	191	194
Total dissolved solids	mg/L	--	6450		1520	1650	1190	1300

NOTES:

Shaded cell indicates exceedance in either the Upper Prediction Limit (UPL) or the Lower Prediction Limit (LPL) for this CCR unit.

Sample Type Code: N - Normal; FD - Field Duplicate

J - Estimated concentration. Qualified due to high matrix spike % recovery.

X - MS/MSD recoveries were outside of the laboratory control limits due to possible matrix interference or a concentration of target analyte high enough to affect the recovery of the spike concentration.

D - Sample was diluted due to targets detected over the highest point of the calibration curve or due to matrix interference.

April 2019 Groundwater Sample Results
CCR Unit: Fly Ash Landfill
CPS Energy Calaveras Power Station
San Antonio, TX

				CCR Unit	FAL	FAL	FAL	FAL	FAL
				Well Designation	Downgradient	Downgradient	Downgradient	Downgradient	Downgradient
				Well ID	JKS-31	JKS-33	JKS-46	JKS-60	JKS-60
				Sample Date	4/9/2019	4/9/2019	4/9/2019	4/9/2019	4/9/2019
				Sample Type Code	N	N	N	N	FD
Chemical	Units	2017-2018 LPL - FAL	2017-2018 UPL - FAL						
Boron	mg/L	--	4.22		0.557	1.13	0.997	0.405	0.375
Calcium	mg/L	--	453		295 D	631	212 D	501 D	506 D
Chloride	mg/L	--	380		322	806	13.2	149 X	151
Fluoride	mg/L	--	5.19		0.791	1.23	2.52	0.187 J	0.187 J
pH, Field	SU	3.98	6.73		3.56	5.98	2.85	5.93	5.93
Sulfate	mg/L	--	6370		852	1640	1030	968	976
Total dissolved solid	mg/L	--	11200		1660	2650 JL	1550	2010	2020

NOTES:

Shaded cell indicates exceedance in either the Upper Prediction Limit (UPL) or the Lower Prediction Limit (LPL) for this CCR unit.

Sample Type Code: N - Normal; FD - Field Duplicate

D - Sample was diluted due to targets detected over the highest point of the calibration curve or due to matrix interference.

J - Estimated concentration. Qualified due to high matrix spike % recovery.

JL - Estimated concentration biased low - analyzed outside of recommended holding time.

X - MS/MSD recoveries were outside of the laboratory control limits due to possible matrix interference or a concentration of target analyte high enough to affect the recovery of the spike concentration.

April 2019 Groundwater Sample Results
CCR Unit: Bottom Ash Ponds
CPS Energy Calaveras Power Station
San Antonio, TX

CCR Unit				BAP	BAP	BAP	BAP	BAP	BAP
Well Designation				Downgradient	Downgradient	Downgradient	Downgradient	Downgradient	Downgradient
Well ID				JKS-48	JKS-50R	JKS-52	JKS-52	JKS-55	JKS-56
Sample Date				4/9/2019	4/9/2019	4/9/2019	4/9/2019	4/9/2019	4/9/2019
Sample Type Code				N	N	N	FD	N	N
Chemical	Units	2017-2018 LPL - BAP	2017-2018 UPL - BAP						
Boron	mg/L	--	2.71	2.22	5.85	1.46 X	1.62	0.74	3.85
Calcium	mg/L	--	229	166 D	159 D	195 DX	188 D	165 D	150 D
Chloride	mg/L	--	484	467	70	336	339	438	81
Fluoride	mg/L	--	0.834	1.46	0.319 J	0.831	0.799	0.822	0.372 J
pH, Field	SU	5.48	7.19	7.06	6.8	6.91	6.91	6.9	6.76
Sulfate	mg/L	--	389	271	168	268	285	168	193
Total dissolved solids	mg/L	--	1870	1420	842	1170	1250	1420	918

NOTES:

Shaded cell indicates exceedance in either the Upper Prediction Limit (UPL) or the Lower Prediction Limit (LPL) for this CCR unit.

Sample Type Code: N - Normal; FD - Field Duplicate

D - Sample was diluted due to targets detected over the highest point of the calibration curve or due to matrix interference.

J - Estimated concentration. Qualified due to high matrix spike % recovery.

X - MS/MSD recoveries were outside of the laboratory control limits due to possible matrix interference or a concentration of target analyte high enough to affect the recovery of the spike concentration.

April 2019 Groundwater Sample Results
CCR Unit: SRH Pond
CPS Energy Calaveras Power Station
San Antonio, TX

				CCR Unit	SRH Pond	SRH Pond	SRH Pond	SRH Pond
				Well Designation	Downgradient	Downgradient	Downgradient	Downgradient
				Well ID	JKS-52	JKS-52	JKS-53	JKS-54
				Sample Date	4/10/2019	4/10/2019	4/10/2019	4/10/2019
				Sample Type Code	N	FD	N	N
Chemical	Units	2017-2018 LPL - SRH	2017-2018 UPL - SRH					
Boron	mg/L	--	2.71		1.46 X	1.62	1.42	1.38
Calcium	mg/L	--	231		195 DX	188 D	116	117
Chloride	mg/L	--	476		336	339	354	385
Fluoride	mg/L	--	0.816		0.831	0.799	0.27 J	0.711
pH, Field	SU	5.48	7.19		6.91	6.91	6.6	6.75
Sulfate	mg/L	--	382		268	285	224	309
Total dissolved solids	mg/L	--	1830		1170	1250	1150	1470

NOTES:

Shaded cell indicates exceedance in either the Upper Prediction Limit (UPL) or the Lower Prediction Limit (LPL) for this CCR unit.

Sample Type Code: N - Normal; FD - Field Duplicate

D - Sample was diluted due to targets detected over the highest point of the calibration curve or due to matrix interference.

J - Estimated concentration. Qualified due to high matrix spike % recovery.

X - MS/MSD recoveries were outside of the laboratory control limits due to possible matrix interference or a concentration of target analyte high enough to affect the recovery of the spike concentration.